

5.10.3.2 MPS Raster Work Sheet

FEL Dump Worksheet

George Biallas

2/4/98

- This work sheet calculates the burn through times for the FEL Dumps per the available information on 2/4/98 and is derived from a worksheet by Mark Wiseman.
- The information derived is used to generate the FEL MPS Requirements Matrix
- Additional comments, and documentation are provided in the Bibliography at the bottom of the sheet
- All Time to Melt calculations assume no LCW cooling and are within the +-1 Sigma Volume
- Numbers in bold are input points upon which other numbers depend
- Single Failures with times to shut off in the tens of milisec. are most significant.

Constants:

Copper Density	gr/cm ³	8.9
Copper Specific Heat	J/gr/K	0.385
Melt Temp Of Copper	C	1080

OG Dump (Injector Tune Up)

Notes

1. From analysis by B. Yunn
2. Assumed to be 2 Σ Radius

		Expanders & Raster on	Loss of Central Expander	Loss of 10 % Current Center Expander	Loss of Raster	Loss of 20 % Raster Current	Loss of Both Expanders & Raster
Beam Energy	MeV	10	10	10	10	10	10
Beam Current	mA	5	5	5	5	5	5
Reduction in beam spot from central expander at above drop in current (Note 1)	%	NA	NA	20	NA	NA	NA
Center Expander Quad (MQG0G02) Current (Note 1)	A	1.5	0	1.35	1.5	1.5	1.35
1 Sigma	cm	1.4	0.4	1.25	1.4	1.4	0.4
Radius of Circular Raster (Note 2)	cm	2.8	2.8	2.80	0	2.24	0
Outer Radius of Rastered +1 Σ Circle	cm	4.2	3.2	4.0522	1.4	3.64	0.4
Inner Radius of Rastered -1 Σ Circle	cm	1.4	2.4	1.5478	NA	0.84	NA
+3 Σ Rastered Spot Dia.	cm	14	8	13.11	8.4	12.88	2.4
ID of dump at Face	cm	19.68	19.68	19.68	19.68	19.68	19.68
Centering Tolerance +- Penetration Dpth	cm	2.8	5.8	3.3	5.6	3.4	8.6
% Absorbed in Pen. Depth	%	100	100.00	100.00	100.00	100.00	100.00
Angle of Dump Face to Beam	deg.	30	30	30	30	30	30
Area of +-1 Σ on Dump Face	cm ²	98.52	28.15	88.12	12.32	78.82	1.01
Total Beam Power	kW	50	50	50	50	50	50
Vol. of Copper	cm ³	29.56	8.44	26.44	3.69	23.64	0.30
Mass of copper	gr	263.05	75.16	235.28	32.88	210.44	2.68
Percent of Power in +-2 Σ	%	68.00	68.00	68.00	68.00	68.00	68.00
Beam Power in volume	kW	34.00	34.00	34.00	34.00	34.00	34.00
Rate of Temp. Rise	K/sec	336	1175	375	2686	420	32901
Time To Melt	sec	3.22	0.92	2.88	0.40	2.57	0.03
Recommended shut off time from particular failure	sec		0.092	0.288	0.040	0.257	0.003
Recommended shut off time from LCW failure	sec	0.32					

Raster to Dump Face	cm	165.3
Raster Angle from CL	Rad	0.01694
Raster Angle from CL	Deg	0.97043
Field Integral	G-cm	564.953
G-cm/amp	G-cm/A	252
Current Required for Raster	A	2.24188

5.10.3.2 MPS Raster Work Sheet

2G First Light Dump		Minimum Defocus						
		Normal Defocus & Rasters on	Normal Defocus Loss of 2 Rasters	Both Rasters on	Loose V. Raster	Loss of 10 % Vert. Raster	Loose H. Raster	Loss of 10 % Horiz. Raster
Beam Energy	MeV	42	42	42	42	42	42	42
Beam Current	mA	1.1	1.1	1.1	1.1	1.1	1.1	1.1
Penetration Depth	cm	1.33	1.33	1.33	1.33	1.33	1.33	1.33
% Absorbed in Pen. Depth	%	60	60	60	60	60	60	60
Total Beam Power	kW	46.2	46.2	46.2	46.2	46.2	46.2	46.2
1 Sigma Vertical	cm	0.22	0.22	0.06	0.06	0.06	0.06	0.06
Radius of Vertical Raster	cm	3.5	0	3.5	0	3.15	3.5	3.5
Vert. Raster + 2 Sigma	cm	7.44	0.44	7.12	0.12	6.42	7.12	7.12
+3Σ Rastered Height	cm	8.32	1.32	7.36	0.36	6.66	7.36	7.36
Percent of Power in 2 Σ	%	68.00	68.00	68.00	68.00	68.00	68.00	68.00
1 Sigma Horizontal	cm	0.22	0.22	0.06	0.06	0.06	0.06	0.06
Radius of Horizontal Raster	cm	3.5	0	3.5	3.5	3.5	0	3.15
Horizontal. Raster + 2 Sigma	cm	7.44	0.44	7.12	7.12	7.12	0.12	6.42
+3Σ Rastered Width	cm	8.32	1.32	7.36	7.36	7.36	0.36	6.66
+3Σ Rastered Diagonal	cm	11.8	1.9	10.4	7.4	9.9	7.4	9.9
+3Σ Rastered Diagonal	in	4.6	0.7	4.1	2.9	3.9	2.9	3.9
Greatest angle of Beam to Dump Face	deg.	20	10	20	10	10	10	10
2 Σ Area @ Dump face	cm^2	161.84	1.11	148.22	4.92	263.24	4.92	263.24
Vol. of Copper	cm^3	215.25	1.48	197.13	6.54	350.10	6.54	350.10
Mass of copper	gr	1915.73	13.20	1754.48	58.24	3115.91	58.24	3115.91
Beam Power in volume	kW	18.85	18.85	18.85	18.85	18.85	18.85	18.85
Rate of Temp. Rise	K/sec	26	3710	28	841	16	841	16
Time To Melt (1)	sec	42.26	0.29	38.70	1.28	68.73	1.28	68.73
Recommended shut off time	sec		0.0291	3.8702	0.1285	6.8733	0.1285	6.8733
Shut off time from LCW failure	sec	4.23						
Vertical Raster Frequency	Hz	37						
Compare to 1/4 Vertical Raster Period	sec	0.0068						
Horizontal Raster Frequency	Hz	600						
Compare to 1/4 Horizontal Raster Period	sec	0.0004						